



---

## ADDENDUM #1

Request for Quotations  
Evanston Replace Baseboard Heaters  
Solicitation No. 2018-9165

Originally Issued January 15, 2018

### Addendum 1 – Issued January 25, 2018

To Offerors:

The following additions, deductions, changes and corrections to the proposal and specifications for the above referenced project shall hereby be incorporated into the work, and their affect on the proposal shall be reflected in the Offeror's proposal. Offerors shall also verify this fact by indicating the receipt of the addendum in their proposal.

---

### QUESTIONS:

1. How many units are required? **Change quantity from 29 to 27**
2. Are the new units housing finished to match existing? **Baseboard heater housing finish shall be Powder coated dark bronze.**
3. What is the voltage of the units? **Units Voltage is 227 volts 1 phase**
4. Are the units on one circuit of multiples? **The units are wired in 7 different circuits.**

\*\*\*END OF ADDENDUM TO DATE 1/25/18\*\*\*

1627 WESTERN AVENUE, CINCINNATI, OHIO 45214

Phone: (513) 333-0670 Fax: (513) 977-5606 TDD: (513) 977-5807 Website: [www.cintimha.com](http://www.cintimha.com)

Equal Opportunity Employer, Equal Housing Opportunities