






























BRANCH CIRCUIT SYMBOLS		
	HOME RUN TO PANEL, LETTER DESIGNATIONS PANEL, NUMBERS INDICATE CIRCUITS (#12, #12 GROUND) IN 3/4" CONDUIT (MINIMUM) UNLESS OTHERWISE NOTED.	
	CONDUIT STUB OUT, CAP, MARK, AND RECORD.	
	CONDUIT CONTINUATION.	
	CONDUIT TURNING UP.	
	CONDUIT TURNING DOWN.	
LIGHTING SYMBOLS		
	CEILING MOUNTED, DECORATIVE LIGHT FIXTURE. REFER TO LIGHTING FIXTURE SCHEDULE.	
	WALL MOUNTED, DECORATIVE LIGHT FIXTURE. REFER TO LIGHTING FIXTURE SCHEDULE.	
	FLUORESCENT CEILING MOUNTED LIGHT FIXTURE, REFER TO LIGHTING FIXTURE SCHEDULE.	
	EXIT SIGN, CEILING MOUNTED, SHADING INDICATES DIRECTION AND NUMBER OF FACES, ARROWS AS REQUIRED. REFER TO LIGHTING FIXTURE SCHEDULE.	
(3)  (R)	SINGLE POLE SWITCHES, WALL MOUNTED AT 48" A.F.F. (MAXIMUM). SUBSCRIPTS AT SYMBOL INDICATE THE FOLLOWING: 3 – THREE WAY 4 – FOUR WAY a,b,c,d,e – DENOTES CONTROL OF LIGHT FIXTURES WITH CORRESPONDING DESIGNATIONS. R – INDICATES SWITCH CONTROLS "RECEPTACLE" LOCATED IN THIS ROOM AND/OR AREA.	
	EMERGENCY EGRESS LIGHTING BATTERY PACK. REFER TO LIGHTING FIXTURE SCHEDULE.	
POWER SYMBOLS		
(C) (WP) (x) (#)	DUPLEX RECEPTACLE FLUSH IN WALL AT 18" A.F.F. OR AS NOTED. THE FOLLOWING DESIGNATIONS INDICATE SPECIFIC USAGE OR MOUNTING HEIGHT; C – INSTALL 7" ABOVE COUNTER. G – PROVISION OF A GFCI TYPE RECEPTACLE. WP – INSTALL DEVICE IN A WEATHERPROOF ENCLOSURE. x" – HEIGHT (IN INCHES) INSTALLED ABOVE FINISHED FLOOR TO CENTERLINE. # – INDICATES DEVICE CONNECTED TO REFERENCED CIRCUIT NUMBER.	
	DOUBLE DUPLEX RECEPTACLE FLUSH IN WALL AT 18" A.F.F.	
	DUPLEX RECEPTACLE WITH BOTTOM RECEPTACLE WIRED FOR "SWITCHED" OPERATION. MAINTAIN TOP RECEPTACLE FOR GENERAL USE TO FOR COMPLIANCE WITH SPACING CRITERIA RELATED TO N.E.C. ARTICLE #210.52 AND #210.70(A)(1).	
	FLUSH MOUNTED ELECTRICAL PANELBOARD OR LOAD CENTER. REFER TO PANEL SCHEDULE. (DESIGNATION AS INDICATED).	
	SURFACE MOUNTED ELECTRICAL PANELBOARD OR LOAD CENTER. REFER TO PANEL SCHEDULE. (DESIGNATION AS INDICATED).	
	FUSED DISCONNECT SWITCH, HEAVY DUTY, HP RATED WITH FUSES PER EQUIPMENT MANUFACTURER AND WEATHERPROOF AS REQUIRED. PROVIDE FINAL CONNECTION TO UNIT EQUIPMENT.	
	UN-FUSED, NEMA 1 DISCONNECT SWITCH, HEAVY DUTY, HP RATED, NEMA 3R WHERE REQUIRED. PROVIDE FINAL CONNECTION TO UNIT EQUIPMENT.	
	JUNCTION BOX, CEILING MOUNTED. SIZE AND TYPE AS REQUIRED. REFER TO DRAWINGS.	
	JUNCTION BOX, WALL MOUNTED. SIZE AND TYPE AS REQUIRED. REFER TO DRAWINGS.	
	DOORBELL A/V SYSTEM FOR UFAS UNIT – A/V DEVICE	
	DOORBELL A/V SYSTEM FOR UFAS UNIT – PUSHBUTTON DEVICE	
FIRE ALARM SYMBOLS		
 (A/V)	SINGLE/MULTIPLE STATION FIRE ALARM SMOKE DETECTOR, CEILING MOUNTED WITH 120 VOLT AND BATTERY BACKUP CONNECTIONS. AN "A/V" DESIGNATION INDICATES DEVICE WITH "AUDIBLE/VISUAL" DEVICE/ACCESSORY FOR ALL U.F.A.S. APARTMENTS.	
	FIRE ALARM "AUDIBLE/VISUAL" DEVICE CONNECTED TO APARTMENT SMOKE DETECTOR IN ALL U.F.A.S. APARTMENTS. INSTALL 80" A.F.F. (MAXIMUM).	
	FIRE ALARM "VISUAL" ONLY DEVICE IN ALL U.F.A.S. APARTMENTS. INSTALL 80" A.F.F. (MAXIMUM).	
	EMERGENCY CALL PULL STATION INSTALLED 42" A.F.F. (MAXIMUM).	
COMMUNICATION SYMBOLS		
	WALL TYPE TELEPHONE JACK (TYPE "RJ11") WITH OUTLET BOX, CATEGORY 3 CABLEING AND WALL TELEPHONE TYPE FACEPLATE MOUNTED 48" A.F.F. PROVIDE A 4S (MINIMUM) BOX WITH A SINGLE GANG TRIM RING.	
	COMBINATION TELEPHONE JACK (TYPE "RJ11") AND TELEVISION JACK (TYPE "T") WITH OUTLET BOX, DUAL RG/6 COAXIAL CABLEING, CATEGORY 3 TELEPHONE CABLEING AND DUAL FACEPLATE MOUNTED 18" A.F.F. PROVIDE A 4S (MINIMUM) BOX WITH A SINGLE GANG TRIM RING.	
ANNOTATIONS		
A1	LIGHTING FIXTURE DESIGNATION, "A1" INDICATES FIXTURE TYPE REFER TO LIGHTING FIXTURE SCHEDULE ON DRAWINGS.	
	PLAN NOTE REFERENCE, REFER TO NOTES ON SHEET, OR AS DIRECTED.	
	REFERENCE FOR APARTMENT APPLIANCE ELECTRICAL CONNECTION. REFER TO TYPICAL UNIT APPLIANCE CONNECTION SCHEDULE.	
ABBREVIATIONS		
A AMPERE	EXIST EXISTING	MC MECHANICAL CONTRACTOR
A/C AIR CONDITIONING	GC GENERAL CONTRACTOR	NL NIGHT LIGHT
AFF ABOVE FINISHED FLOOR	GFCI GROUND FAULT CIRCUIT	NTS NOT TO SCALE
C/B CIRCUIT BREAKER	INT INTERRUPTER	OFE OWNER FURNISHED EQUIPMENT
CKT CIRCUIT	GRND GROUND	PC PLUMBING CONTRACTOR
DR DUPLEX RECEPTACLE	JB JUNCTION BOX	TYP TYPICAL
EMT ELECTRICAL METALLIC	LTC LIGHTING	UON UNLESS OTHERWISE NOTED

GENERAL ELECTRICAL DEMOLITION NOTES:

- IT IS THE ELECTRICAL SCOPE OF WORK AND INTENT FOR THE ELECTRICAL CONTRACTOR TO COMPLETELY REMOVE AND REPLACE ALL ELECTRICAL EQUIPMENT, DEVICES, PANELS, WIRING, ELECTRIC SERVICE, ETC. FOR ALL APARTMENTS IN THE PROJECT. THE GENERAL CONTRACTOR WILL BE REMOVING DRYWALL TO ACCOMMODATE THE INSTALLATION OF NEW WORK OUTLINED ON THE ELECTRICAL DRAWINGS. REFER TO THE ARCHITECTURAL AND SPECIFICATIONS AND DRAWINGS OUTLINING THESE REQUIREMENTS. THE ELECTRICAL CONTRACTOR SHALL INCLUDE ALL CUTTING AND PATCHING OF DRYWALL, EXISTING CONDITIONS, ETC. TO INSTALL THE ELECTRICAL WORK INDICATED ON THESE DRAWINGS AND OUTSIDE OF THE SCOPE DESCRIBED IN THE ARCHITECTURAL DOCUMENTS.
- THE INFORMATION INDICATED ON THE DEMOLITION DRAWINGS IS A COMPOSITE OF INFORMATION OBTAINED FROM ACTUAL FIELD CONDITIONS AND/OR EXISTING DRAWINGS. THE INFORMATION SHALL BE CONSIDERED DIAGRAMMATIC.
- INCLUDE ALL COSTS AND LABOR, MATERIALS, EQUIPMENT, SERVICES, AND PERMITS NECESSARY FOR COMPLETION OF THE DEMOLITION WORK. PROVIDE PROTECTION FOR ALL PERSONNEL AND ADJACENT AREAS BEFORE, DURING, AND AFTER EXECUTION OF THE DEMOLITION WORK.
- ELECTRICAL CONTRACTOR SHALL FIELD VERIFY EXTENT OF DEMOLITION PRIOR TO BIDDING AND INCLUDE ALL LABOR, MATERIALS, EQUIPMENT, SERVICES, AND PERMITS NECESSARY FOR COMPLETION OF THE DEMOLITION WORK.
- ELECTRICAL EQUIPMENT INDICATED ON THE DEMOLITION DRAWINGS IS SHOWN TO INDICATE THE EXTENT OF DEMOLITION ONLY, AND IS NOT INTENDED TO BE A RECORD DRAWING OF THE EXISTING CONDITIONS. THE DRAWINGS AND SPECIFICATIONS ESTABLISH THE MINIMUM STANDARDS FOR WORKMANSHIP AND MATERIALS.
- "ELECTRICAL EQUIPMENT" AS USED IN THIS SECTION SHALL REFER TO LIGHTING FIXTURES, LIGHT SWITCHES, CONTROLS, RECEPTACLES, AND ALL OTHER POWER AND COMMUNICATION SYSTEM DEVICES AND ALL ASSOCIATED APPURTENANCES.
- PROVIDE MATERIALS AND EQUIPMENT FOR COMPLETION OF THE DEMOLITION WORK AS DESCRIBED WITHIN THE SPECIFICATIONS AND ON THE DRAWINGS.
- MATERIALS AND EQUIPMENT SHALL BE NEW AND U.L. LABELED FOR THE APPLICATION.
- ELECTRICAL CONTRACTOR SHALL DISCONNECT AND REMOVE ALL DEVICES, CONDUIT, WIRING, ETC. (IN THEIR ENTIRETY) FROM WALLS THAT ARE BEING REMOVED. REFER TO ARCHITECTURAL DEMOLITION PLANS.
- THE CONTRACTOR SHALL REMOVE AND/OR RELOCATE ALL OF THE EXISTING ELECTRICAL WORK MADE NECESSARY BECAUSE OF PROJECT ALTERATIONS AS INDICATED OR IMPLIED ON THE CONTRACT DOCUMENTS OF ALL TRADES. ALL EXISTING ELECTRICAL EQUIPMENT AND SYSTEMS NOT AFFECTED BY THESE CHANGES SHALL REMAIN AND SHALL BE PROTECTED WHETHER SHOWN ON THE DRAWINGS OR NOT. THE CONTRACTOR SHALL MAINTAIN EXISTING CIRCUIT CONTINUITY AS DESCRIBED IN THE SPECIFICATIONS AND ON THE DRAWINGS, OR AS REQUIRED FOR CONTINUED OPERATION OF THE ELECTRICAL EQUIPMENT AND SYSTEMS.
- THE CONTRACTOR SHALL PROVIDE FOR ALL DEMOLITION WORK UNDER THIS CONTRACT IN COMPLETE ACCORDANCE WITH THE CONSTRUCTION PROCEDURE AND PROGRESS SCHEDULE SPECIFIED UNDER DIVISION 1. PROPOSAL SHALL INCLUDE ANY SPECIAL PHASING REQUIREMENTS RELATED TO DEMOLITION WORK AS DESCRIBED IN THE DIVISION 1 SPECIFICATIONS.
- WHERE REQUIRED, RESUPPORT EXISTING CONDUITS AND CABLEING ABOVE CEILINGS BEING REMOVED. ELECTRICALLY DISCONNECT EQUIPMENT TO BE REMOVED AT THE POINT OF POWER SUPPLY. REMOVE CONDUIT AND WIRING FROM EQUIPMENT TO BE REMOVED COMPLETE TO THE POINT OF POWER SUPPLY. CLEARLY MODIFY THE RESPECTIVE PANELBOARD DIRECTORIES TO REFLECT ANY CHANGES MADE THROUGH THIS DEMOLITION.
- WHERE BUILDING SYSTEMS OR CIRCUITS ARE INTERRUPTED BECAUSE OF THE DEMOLITION WORK, THEY SHALL BE REROUTED OR RELOCATED, MODIFIED AND RECONNECTED TO PROVIDE A CONTINUOUS SYSTEM FOR ALL AREAS OUTSIDE OF THE CONTRACT AREA.
- ALL CUTTING, PATCHING, FINISHING, ETC., FOR REMOVAL AND RELOCATING ELECTRICAL EQUIPMENT SHALL BE INCLUDED AS PART OF THE ELECTRICAL WORK UNLESS OTHERWISE NOTED. ALL HOLES AND DAMAGE CAUSED BY THE DEMOLITION WORK SHALL BE PROPERLY PATCHED WITH SUITABLE MATERIALS TO MATCH EXISTING SURFACES AND MAINTAIN FIRE RATING OF RESPECTIVE ASSEMBLY (WALL, FLOOR, ETC.).
- PATCH ALL OPENINGS/HOLES WHEREVER ELECTRICAL DEMOLITION DAMAGES OR DISTURBS EXISTING SURFACES, MATERIALS, ETC. THAT REMAIN. PATCHING SHALL MATCH ADJACENT CONSTRUCTION/FINISHES. COVERPLATES ARE NOT AN ACCEPTABLE PATCH.
- WHERE EXISTING FLOOR SLAB OR CONCRETE WALL IS INDICATED TO REMAIN, BUT HAVE CONDUITS THAT ARE INDICATED TO BE REMOVED, THESE CONDUITS SHALL BE CUT OFF 1/8" BELOW SURFACE AND CAPPED OR PLUGGED. PATCH WALL OR FLOOR AS NECESSARY TO MATCH EXISTING.
- CONDUITS AND WIRING PASSING THROUGH THAT SERVE ELECTRICAL SYSTEMS IN AREAS OUTSIDE THE CONSTRUCTION AREA SHALL REMAIN AND BE PROTECTED WHETHER SHOWN ON THE DRAWINGS OR NOT. THE CONTRACTOR SHALL MAINTAIN EXISTING CIRCUIT CONTINUITY AS REQUIRED FOR CONTINUED OPERATION OF THE ELECTRICAL EQUIPMENT AND SYSTEMS. WHERE REQUIRED, RESUPPORT EXISTING CONDUITS AND CABLEING ABOVE CEILINGS BEING REMOVED.
- ALL EQUIPMENT INDICATED AS BEING REMOVED, SHALL BE CAREFULLY REMOVED AND SECURELY STORED ON SITE BY THE CONTRACTOR FOR SALVAGE BY BUILDING MANAGEMENT OR POSSIBLE REUSE DURING NEW CONSTRUCTION. ALL OTHER MATERIALS, EQUIPMENT AND DEBRIS SHALL BECOME THE PROPERTY OF THE CONTRACTOR AND SHALL BE REMOVED FROM THE SITE.
- CAP EXISTING EMPTY CONDUITS AND PLUG OPEN KNOCKOUTS IN EXISTING ELECTRICAL EQUIPMENT.

GENERAL ELECTRICAL CONSTRUCTION NOTES:


- EQUIPMENT AND MATERIAL USED ON THIS PROJECT SHALL BE NEW AND U.L. LABELED FOR THE APPLICATION.
- WORK SHALL BE INSTALLED IN ACCORDANCE WITH ALL APPLICABLE PROVISIONS OF LOCAL AND STATE CODES AS WELL AS THE NATIONAL ELECTRICAL CODE (NEC), AS INTERPRETED BY THE LOCAL AUTHORITY HAVING JURISDICTION.
- MATERIAL OR LABOR WHICH IS NOT INDICATED ON THE DRAWINGS OR SPECIFICATION BUT WHICH IS OBVIOUSLY NECESSARY TO COMPLETE THE WORK SHALL BE PROVIDED. DRAWINGS AND SPECIFICATIONS ARE TO BE CONSIDERED AS SUPPLEMENTING EACH OTHER.
- VISIT THE SITE OF THE WORK AND BECOME FAMILIAR WITH CONDITIONS AFFECTING THE INSTALLATION. SUBMISSION OF A PROPOSAL SHALL PRESUPPOSE KNOWLEDGE OF SUCH CONDITIONS AND NO ADDITIONAL COMPENSATION SHALL BE ALLOWED WHERE EXTRA LABOR OR MATERIALS ARE REQUIRED BECAUSE OF IGNORANCE OF THESE CONDITIONS.
- WHERE LIGHT SWITCHES ARE SHOWN ADJACENT TO ONE ANOTHER, THEY SHALL BE GROUPED TOGETHER INTO A 2, 3, OR 4 GANG DEVICE BOX WITH COMMON COVERPLATE.
- BACKBOXES IN DEMISING WALLS SHALL NOT BE ROUGHED-IN BACK TO BACK IN THE SAME STUD SPACE. PROVIDE FIRE-STOPPING AS REQUIRED TO MAINTAIN FIRE RATING.
- REFER TO ARCHITECTURAL ELEVATIONS FOR MOUNTING LOCATION AND HEIGHT OF ALL WIRING DEVICES.
- COORDINATE THE EXACT LOCATION OF ALL RECEPTACLES AT CABINET LOCATIONS WITH G.C. CUT AND PATCH AS DIRECTED BY THE G.C.
- ALL DEVICES SHALL BE RESIDENTIAL GRADE, 20 AMP DEVICES. RECEPTACLES SHALL BE TAMPER RESISTANT TYPE IN COMPLIANCE WITH N.E.C. #406.12.
- SMOKE DETECTORS MUST BE INSTALLED FREE OF DUST OR ANY OTHER CONTAMINATION. LOCATE A MINIMUM OF 3'-0" FROM ALL SUPPLY AIR DIFFUSERS.
- WHERE OUTLETS IN A STUD PARTITION OF ADJACENT ROOMS ARE SIMILAR AND ARE FIRE RATED THE OUTLETS SHALL BE STAGGERED, AND FIRE (PUTTY) PADS SHALL BE PROVIDED.
- ALL WORK SHALL BE INSTALLED IN ACCORDANCE WITH THE CURRENT N.E.C. WITH SPECIFIC ATTENTION TO ARTICLE #210.8(A), #210.12(A) AND #210.52 FOR DWELLING UNIT ELECTRICAL REQUIREMENTS, LOCATIONS, ETC.
- MULTI STATION SMOKE DETECTORS SHALL BE PROVIDED WITH TWO SOURCES OF POWER (120 VOLT AND BATTERY BACK-UP) IN ACCORDANCE WITH N.F.P.A. REQUIREMENTS.
- ALL PENETRATIONS IN FIRE RATED FLOORS, SHAFTS AND WALLS SHALL BE FIRE STOPPED. THE INSTALLATION OF FIRE STOPPING MATERIALS SHALL CONFORM TO THE LATEST FIRE RESISTANCE DIRECTORY AS PUBLISHED BY U.L.
- WIRE AND CABLE FOR POWER AND LIGHTING BRANCH CIRCUITS AND FEEDERS SHALL BE COPPER STRANDED (SOLID FOR #12AWG). 600 VOLT TYPE THHN/THWN OR THHN/THWN COPPER. NON-METALLIC SHEATHED CABLE (TYPE "NMCT") MAY BE UTILIZED FOR ALL BRANCH CIRCUIT WIRING. INSTALLATION SHALL BE IN ACCORDANCE WITH N.E.C. ARTICLE #334.
- GROUNDING OF THE ELECTRICAL SYSTEM SHALL BE BY MEANS OF AN INSULATED GROUNDING CONDUCTOR INSTALLED WITH CIRCUIT CONDUCTORS. GROUNDING CONDUCTORS SHALL BE SIZED IN ACCORDANCE WITH N.E.C. 250.122 AND SHALL RUN FROM GROUNDING BUS OF SERVING PANEL TO GROUND SCREW OF ALL WIRING DEVICES AND METAL ENCLOSURES.
- CONDUITS (WHERE REQUIRED) SHALL BE RIGID GALVANIZED, EMT OR INTERMEDIATE. ALL CONDUITS SHALL BE GROUNDED AND BONDED WITH A RELATED GROUNDING BUSHINGS AT ALL EQUIPMENT ENCLOSURES VIA GROUNDING LUG/BUS IN ADDITION TO A COPPER CONDUCTOR INSTALLED WITH CIRCUIT CONDUCTORS SIZED IN ACCORDANCE WITH N.E.C. ARTICLE 250 (BUT NOT SMALLER THAN #12 AWG). PROVIDE SCHEDULE 40 PVC FOR ALL UNDERGROUND USE WITH GROUND WIRE INSTALLED WITH CIRCUIT CONDUCTORS.
- GUARANTEE ALL WORKMANSHIP AND MATERIALS PROVIDED UNDER THE CONTRACT FOR ONE YEAR AFTER ACCEPTANCE BY THE OWNER AND COMPLETION OF ALL PUNCH LIST ITEMS. REPAIR OR REPLACE ANY DEFECT WITHOUT COST TO THE OWNER.
- AFTER INSTALLATION BUT PRIOR TO ENERGIZATION, PERFORM TESTS FOR GROUNDS, SHORT CIRCUITS AND PROPER FUNCTION. FAULTS IN THE INSTALLATION SHALL BE CORRECTED.
- AFTER ALL TESTS HAVE BEEN COMPLETED, CLEAN ALL EQUIPMENT LEAVING EVERYTHING IN WORKING ORDER AT THE COMPLETION OF THIS WORK.
- EXCEPT WHERE OTHERWISE SPECIFIED OR NOTED ON DRAWINGS, THE ELECTRICAL CONTRACTOR SHALL PERFORM ALL CUTTING AND PATCHING OF THE BUILDING AS REQUIRED INSTALLING SLEEVES, INSERTS, CONDUITS AND ELECTRICAL EQUIPMENT. PATCHING SHALL BE DONE BY SKILLED MECHANICS. WORK SHALL MATCH THE GENERAL CONSTRUCTION WORK. ALL CUTTING SHALL BE DONE IN A MANNER TO RETAIN THE STRUCTURAL INTEGRITY OF THE UNIT BEING CUT.

LIGHTING FIXTURE SCHEDULE					
TYPE	WATTAGE		DESCRIPTION	CATALOG NO.	EQUIVALENT MANUFACTURER
	LAMP	FIXTURE			
A1	4-13 QUAD 4-PIN GX240-1	60	FLUORESCENT "CLOSE TO CEILING" FIXTURE 20" IN DIAMETER WITH WHITE ACRYLIC "CLOUD" DIFFUSER (120V).	PROGRESS #P7311	—
B1	2-F17 18 2700K 85 CRI	32	FLUORESCENT VANITY FIXTURE 24.5" IN LENGTH WITH STEEL HOUSING, WHITE ACRYLIC DIFFUSER, CHROME END CAPS AND HPF ELECTRONIC BALLAST (120V).	PROGRESS #P7230-15EB	—
C1	2-T5 CFT/PLT 3500K CRI 82	20	FLUORESCENT UNDER-CABINET FIXTURE 24" IN LENGTH WITH STEEL HOUSING AND ACRYLIC LENS (120V).	PROGRESS #PS014-30	—
D1	1-18 QUAD/GFL 4-PIN —	20	FLUORESCENT DECORATIVE EXTERIOR WALL MOUNTED FIXTURE WITH WHITE ACRYLIC ACORN STYLE DIFFUSER, POLYPROPYLENE CONSTRUCTION, INTEGRAL PRE-WIRED PHOTOCELL, U.L. "WET LOCATION" RATING AND NPFF ELECTRONIC BALLAST (120V).	PROGRESS #P3881-31EB	—
E1	LED 4000k	35	LED UTILITY TYPE EXTERIOR FIXTURE WITH INTEGRAL MOTION/OCCUPANCY SENSING FEATURE (120V).	—	—
F1	LED 4000k	45	LED DECORATIVE EXTERIOR FIXTURE WITH INTEGRAL MOTION/OCCUPANCY SENSING FEATURE (120V).	—	—
G1	2-32 4000k	58	FLUORESCENT SURFACE MOUNTED FIXTURE 4'-0" IN LENGTH WITH INTEGRAL OCCUPANCY SENSOR, ACRYLIC DIFFUSER, STEEL HOUSING AND ELECTRONIC BALLAST (120V).	—	—
H1	2-32 4000k	58	FLUORESCENT SURFACE MOUNTED VANDAL RESISTANT FIXTURE 4'-0" IN LENGTH WITH INTEGRAL OCCUPANCY SENSOR, ACRYLIC DIFFUSER, STEEL HOUSING, U.L. "WET LOCATION" LABEL AND ELECTRONIC BALLAST (120V).	—	—

LIGHTING FIXTURE SCHEDULE NOTES:

- THE E.C. SHALL COORDINATE COLORS, FINISHES, LENGTHS, ETC. OF ALL LIGHT FIXTURES WITH THE ARCHITECT AND ACTUAL FIELD CONDITIONS PRIOR TO PLACING PURCHASE ORDER.
- THE E.C. SHALL COORDINATE ALL TRIMS OF LIGHT FIXTURES WITH ARCHITECTURAL REFLECTED CEILING PLANS, EXISTING CONDITIONS, ETC. AND INCLUDE APPROPRIATE TRIM (LAY-IN, DRYWALL, ETC.) IN BASE BID. SUBMISSION OF SHOP DRAWINGS WILL BE INTERPRETED THAT THIS COORDINATION WITH THE ARCHITECT HAS BEEN COMPLETED AND NO ADDITIONAL COMPENSATION WILL BE ALLOWED DUE TO THE LACK OF THIS COORDINATION.
- THE E.C. SHALL REFER TO ELECTRICAL SPECIFICATIONS FOR ALLOWABLE LAMP AND BALLAST MANUFACTURERS.
- ALL LIGHT FIXTURES ARE REQUIRED TO BE "ENERGY STAR" RATED.
- THIS LIGHT FIXTURE WAS SELECTED BY THE ARCHITECT. ALTERNATE MANUFACTURER'S MAY BE PROVIDED, HOWEVER, APPROVAL MUST BE OBTAINED PRIOR TO SUBMITTING BASE BID OR CONTRACT PRICE.

DATE	DESCRIPTION
10.23.2013	Issued for 60% Owner Review
11.06.2013	Issued for 100% Owner Review
12.09.2013	Issued for Permit and Bidding



a 3109 Mayfield Road, Suite 201
Cleveland, OH 44118
w www.LDAarchitecture.com

p 216.932.1890
f 216.932.1891

Horizon Hills
Cincinnati Metropolitan Housing Authority
Intersection at Grand and Warsaw Avenue,
Cincinnati, OH 45204

LDA Project No. 13.25

Electrical Legends,
Schedules & Notes

E1.01