



---

## **ADDENDUM #1**

Invitation for Bids  
RIVERVIEW – CHILLER CONDENSING UNIT REPLACEMENT  
AND AIR HANDLER CLEANING  
Solicitation No. 2022-3016

Cincinnati Metropolitan Housing Authority  
1627 Western Avenue  
Cincinnati, OH 45214

### **Addendum 1 – Issued April 21, 2022**

To Offerors:

The following additions, deductions, changes and corrections to the proposal and specifications for the above referenced project shall hereby be incorporated into the work, and their affect on the proposal shall be reflected in the Offeror's proposal. Offerors shall also verify this fact by indicating the receipt of the addendum in their proposal.

---

### **Comments**

1. There are several pipes and ducts above the air handler unit, which allows moisture to accumulate on the top of the air handler unit. Contractor will need install a stainless steel pan over the top of the entire unit to protect it from further corrosion. The pan must drain to a pipe that leads to the closest floor drain.
2. The Pre Bid attendance sheet is attached.

**1627 WESTERN AVENUE, CINCINNATI, OHIO 45214**

**Phone:** (513) 333-0670 **Fax:** (513) 977-5606 **TDD:** (513) 977-5807 **Website:** [www.cintimha.com](http://www.cintimha.com)

Equal Opportunity Employer, Equal Housing Opportunities

