



ADDENDUM 1

Issue Date September 29, 2023

Solicitation 2023-3022

To Offerors:

The following additions, deductions, changes and corrections to the proposal and specifications for the above referenced project shall hereby be incorporated into the work, and their effect on the proposal shall be reflected in the Offeror's proposal. Offerors shall also verify this fact by indicating the receipt of the addendum in their proposal.

Additions, deductions, changes and/or corrections:

Questions:

Where to get power?

- There are no power outlets on the common areas of Floors 1 through 7.
- Contractor is responsible to power its tool.

Should the laundry floor pitch need to be maintained?

- The pitch to the floor drains needs to be maintained or reestablish if needed.

Has an asbestos survey been performed on the flooring and mastic/glue for this project?

If so, will there be an abatement element to this project?

- No, no survey has been performed. When removal of existing flooring is required shall be treated as it is positive for asbestos and removal shall be per industry standards. Contractor shall provide proper documentation of the disposal for payment.

Change

PART 2 - Scope of Work, Item 5a (page 156) that reads:

remove paint on stair steps changes to replace rubber thread in kind.

Add

PART 2 - Scope of Work, Item 2

Add item d. repair broken cement wall base as needed

Contractor is responsible to move any furniture, office equipment, cubicle walls etc. as needed in order to properly install the flooring.

Walk Through Attendance Sign Sheet is Attached

1627 WESTERN AVENUE, CINCINNATI, OHIO 45214

Phone: (513) 333-0670 Fax: (513) 977-5606 TDD: (513) 977-5807 Website: www.cintimha.com

Equal Opportunity Employer, Equal Housing Opportunities



WALK THROUGH SIGN SHEET

Solicitation 2023-3022

Date Sep 28, 2023

FILL IN BLOCK LETTER

<input type="checkbox"/>	Company / Name Email / Phone No.	<u>CMHA ALBERTO GÓMEZ</u> <u>alberto.gomez@cmha.com 513 615 2870</u>
<input type="checkbox"/>	Company / Name Email / Phone No.	<u>Max Construction Tony Kestel</u> <u>tony.kestel@themaxconstructiongroup.com</u>
<input type="checkbox"/>	Company / Name Email / Phone No.	<u>Max construction Ricky Burdine</u> <u>RickyBurdine @ the maxconstruction group.com</u>
<input type="checkbox"/>	Company / Name Email / Phone No.	<u>Max Construction Brayden Kestel</u> <u>Bkestel@themaxconstructiongroup.com</u>
<input type="checkbox"/>	Company / Name Email / Phone No.	<u>Avery Mobile Auto Care Christopher Avery</u> <u>averyfam.biz@aol.com 513 703-8933</u>
<input type="checkbox"/>	Company / Name Email / Phone No.	<u>Preston Floor Care Willis Preston</u> <u>PrestonFloorcare@gmail.com 513.545.6234</u>
<input type="checkbox"/>	Company / Name Email / Phone No.	_____ _____
<input type="checkbox"/>	Company / Name Email / Phone No.	_____ _____
<input type="checkbox"/>	Company / Name Email / Phone No.	_____ _____
<input type="checkbox"/>	Company / Name Email / Phone No.	_____ _____