

Bid No.: 2024-9047 Addendum 1

Rev 5/24

Winton Terrace Boiler Room Water Alarms 30 Winton Terrace Boiler Rooms

To Offerors:

The following additions, deductions, changes and corrections to the proposal and specifications for the above referenced project shall hereby be incorporated into the work, and their effect on the proposal shall be reflected in the Offeror's proposal. Offerors shall also verify this fact by indicating the receipt of the addendum in their proposal.

Additions, deductions, changes and/or corrections:

1. Clarification: The alarm box should be mounted inside the cages of the Boiler Rooms.

It should be noted that if the alarm box is mounted on the street side, there is a possibility that vandals would break or knock it off the building.